



TEST REPORT

主験 Main Test UPS 12360 7 F2

樣品規格 Specification

輔驗 Additional Test

UPS 12240 6 F2 UPS 12360 6 F2 UPS 12460 F2 UPS 12580 F2

RUM 6290 F2

報告彙整日期 Report compilation date

2024/3/22

報告彙整編號 Report compilation No.

UPS-M01-2403

CSB ENERGY TECHNOLOGY CO., LTD.

Website: //www.csb-battery.com/

TEST REPORT

樣品描述 Sample Description	Valve Regulated Lead Acid Battery	主驗型號 Main Model	UPS 12360 7 F2
批號 Lot no.	220216V21	規格 Specification	See the Table 1
樣品數量 Sample Quantity	30 pcs	樣品狀況 Sample Status	undamaged
收件日期 Sample Received Date	2022/4/6	測試日期 Test Date	Start date : 2022/4/7 End date : 2024/3/22
製造商Manufacturer	CS	B Energy Technology Co.,	Ltd.
地址Address	11F, No. 150, Sec. 4, Chengde Rd., Shilin Dist., Taipei City 111052, Taiwan (R.O.C.)		
委託單位Applicant	CSB Energy Technology Co., Ltd.		
實驗室地址 Test address	No. 16, Gongye W. Rd., EII Jenn Vil., Guantian Dist., Tainan City 72048, Taiwan(R.O.C.)		
測試項目 Test Items	See the Table 2		
測試依據 Test standard	The testing methods of the report are based on IEC 60896-21: 2004 (1), and the testing results are based on IEC 60896-22: 2004 (1).		
測試結果 Test Conclusion	The results conform to the requirements of standards with respect to the test items. (Stamp of Test Unit)		
備註 Remarks	There are 6 models (See the Table 1) for application, shown in this report, with the difference being the outer sizes and capacity. All of the tests were performed on UPS 12360 7 F2. Other models were test by 6.11 Discharge capacity C ₁₀ to confirm status.		

Tested by: 黃亮論
Sign: 英克莎
Date: 2024/3/22

Approved by: 王冠堯 Sign: Date: 2024/3/22

Table 1: Models for application			
No.	Models	Specification	
1	UPS 12240 6 F2	12V/240W	
2	UPS 12360 6 F2	12V/360W	
3	UPS 12360 7 F2	12V/360W	
5	UPS 12460 F2	12V/460W	
6	UPS 12580 F2	12V/580W	
7	RUM 6290 F2	6V/290W	

Table 2: Test items			
Test Clause	Measures	Purpose	
6.1	Gas emission	To determine the emitted gas volume	
6.2	High current tolerance	To verify the adequacy of current conduction cross-sections	
6.3	Short circuit current and dc. Internal resistance	To provide data for the sizing of fuses in the exterior circuit	
6.4	Protection against internal ignition from external spark sources	To evaluate the adequacy of protective features	
6.5	Protection propensity against ground short	To evaluate the adequacy of design features	
6.6	Content markings and durability of required	To evaluate the quality of the markings and the content of the information	
6.8	Valve operation	To ensure the correct opening of safety valves	
6.9	Flammability rating of materials	To verify the fire hazard class of battery materials	
6.10	Intercell connector performance	To verify the maximum surface temperatures of the connectors during high rate discharges	
6.11	Discharge capacity	To verify the available capacities at discharge rates or discharge durations. selected	
6.12	Charge retention during storage	To provide storage duration data	
6.13	Float service with daily discharge	To determine cyclic performance under float charge conditions	
6.14	Recharge behavior	To determine the recovery of capacity or autonomy time after a power outage	
6.15	Service life at an operating temperature of 40 °C	To determine the operational life at temperatures elevated	
6.16	Impact of a stress temperature of 55 °C or 60 °C	To determine the influence of high stress temperatures on cell or monobloc battery life	
6.17	Abusive over-discharge	To determine the expected behavior when excessive capacity is discharged	
6.18	Thermal runaway sensitivity	To determine the expected times to establish a condition of escalating current and temperature	
6.19	Low temperature sensitivity	To determine the sensitivity toward induced by electrolyte freezing damage	
6.20	Dimensional stability at elevated internal pressure and temperature	To determine the propensity of the monobloc battery to be deformed by pressure and at elevated temperature cell or internal	
6.21	Stability against mechanical abuse of units during installation	Determine the propensity of the cell or monobloc battery to fracture or leak when dropped.	

TEST RESULT

	IEC 60896-21:2004, IEC 6089	96-22:2004	
Items	Requirement – Test	Result - Remark	Verdict
	High current tolerance:		Pass
6.2	The test methods are according to clause 6.2.1 to 6.2.6 which are stated in the standard IEC 60896-21	It has no any damage after 30s	
	Requirement and application: Measure unit voltage, inspect and document the status of the top-lead and terminals of each unit after 30 s current flow. Pass for all applications: Voltage of unit >2,0 Vpc; Show evidence of no incipient melting or of no loss of electrical continuity after 30 s of high current flow (value to be stated).	of high current flow. Voltage after the test: No.13: 13.03 V/20.71 m Ω No.14: 13.01 V/20.65 m Ω No.15: 13.02 V/20.89 m Ω	
	Short circuit current and d.c. internal resistance:		
	The test methods are according to clause 6.3.1 to 6.3.6 which are stated in the standard IEC 60896-21	UPS 12360 7 F2:	
6.3	Requirement and application: Define prospective short-circuit value Isc and internal resistance Ri of all units of a type range. State data for all applications: Short-circuit current (Isc) in A; Internal resistance (Ri) in ohms.	No.16: Isc=264 A Ri=0.048 Ω No.17: Isc=264 A Ri=0.048 Ω	State the value
	Requirement and application: see table 8 in the standard IEC 60896-22	No.18: Isc=258 A Ri=0.049 Ω	
	The test methods are according to clause 6.5.1 to 6.5.9 which are stated in the standard IEC 60896-21		
	Content and durability of required markings:		
6.6	The durability of the marking shall be tested according to clause 1.7.13 of IEC 60950-1 and the content of marking shall meet the requirement of IEC 60896-22		
	Requirement and application: Expose information to chemicals.Pass all substances for all applications: Information shall remain readable after exposure to chemicals and remain in place	Information remain readable after test and content meet requirement.	Pass
	Requested information to be present for all applications.		

	IEC 60896-21:2004, IEC 6089	96-22:2004	
Items	Requirement – Test	Result - Remark	Verdict
6.11	Discharge capacity: The test methods are according to clause 6.11.1 to 6.11.12 which are stated in the standard IEC 60896-21 Requirement and application: Determine actual capacity Ca. Ca to be at least X % of Crt with all units at all rates shown below: $10h\ 8h\ 3h\ 1h\ 0.25h$ $1.80Vpc\ 1.75Vpc\ 1.70Vpc\ 1.60Vpc\ Comply for all applications: Ca \ge 95\ \%\ Crt$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	Pass
6.12	Charge retention during storage The test methods are according to clause 6.11.1 to 6.11.12 which are stated in the standard IEC 60896-21 Requirement and application: see table 16 in the standard IEC 60896-22	UPS 12360 7 F2: Charge retention factor UPS 12360 7 F2: No.7: Crf = 86.5 % No.8: Crf = 87.0 % No.9: Crf = 88.3 % No.10: Crf = 87.8 % No.11: Crf = 85.8 % No.12: Crf = 91.0 %	Pass
6.14	Recharge behavior: The test methods are according to clause 6.14.1 to 6.14.12 which are stated in the standard IEC 60896-21 Requirement and application: Determine capacity after recharge; Rbf24h (24 h Recharge behaviour factor), Rbf168h (168 h Recharge behaviour factor). Comply for all applications: ≥90 %, ≥98 % (NOTE The requirement applies not to the average but to each of the individual tested units.)	UPS 12360 7 F2: Rbf24h=96.9 % Rbf168h =101.0 %	Pass

	IEC 60896-21:2004, IEC 60896-22:2004				
Items	Requirement – Test	Result - Remark	Verdict		
6.17	Abusive over-discharge: The test methods are according to clause 6.17.1 to 6.17.15 which are stated in the standard IEC 60896-21	UPS 12360 7 F2: Unbalanced string over-discharge capacity Caod: Caod = 0.88 Crt(3h rate)	Pass		
	Requirement and application: see table 21 in the standard IEC 60896-22	Cyclic over-discharge capacity Caoc: Caoc=0.90 Crt(3h rate)			
	Impact of low temperature service on capacity		Pass		
6.19	The test methods are according to clause 6.19.1 to 6.19.13 which are stated in the standard IEC 60896-21	No mechanical damages UPS 12360 7 F2: No.11: Cals = 0.96 Crt No.12: Cals = 0.97 Crt			
	Requirement and application: see table 23 in the standard IEC 60896-22	No.13: $Cals = 0.99 Crt$			
	Stability against mechanical abuse of units during installation				
6.21	The test methods are according to clause 6.21.1 to 6.21.6 which are stated in the standard IEC 60896-21	No leakage, No broken	Pass		
	Requirement and application: see table 25 in the standard IEC 60896-22				

ANNEX B : Additional Test 6.11 Discharge capacity C10		
Models	No.	% of Crt
	1	103.4
	2	103.9
LIDG 12240 (F2	3	104.1
UPS 12240 6 F2	4	102.6
	5	103.2
	6	103.7
	1	104.3
	2	103.4
LIDG 122(0 (F2	3	101.8
UPS 12360 6 F2	4	104.8
	5	105.1
	6	104.9
	1	102.6
	2	103.1
LIDG 12460 F2	3	102.0
UPS 12460 F2	4	101.2
	5	101.8
	6	102.1
	1	105.7
	2	104.2
LIDG 12500 F2	3	104.3
UPS 12580 F2	4	104.5
	5	105.4
	6	104.4
	1	105.7
	2	103.8
DIM (200 F2	3	104.2
RUM 6290 F2	4	105.8
	5	105.4
	6	105.2

Table 3: Mian Test Report Number (UPS 12360 7 F2)		
Test Clause	Measures	Report No.
6.2	High current tolerance	RL22051102-01
6.3	Short circuit current and dc. Internal resistance	RL22050202-01
6.6	Content markings and durability of required	RL22051101-01
6.11	Discharge capacity	RL22050301-01
6.12	Charge retention during storage	RL21120802-01
6.14	Recharge behavior	RL22051901-01
6.17	Abusive over-discharge	RL24032101-01
6.19	Low temperature sensitivity	RL24032201-01
6.21	Stability against mechanical abuse of units during installation	RL22051902-01

Table 4: Additional Test Report Number			
Test Clause	Measures	Report No.	
	Discharge capacity (UPS 12240 6 F2)	RL24030701-01	
6.11	Discharge capacity (UPS 12360 6 F2)	RL24030801-01	
	Discharge capacity (UPS 12460 F2)	RL24010201-01	
	Discharge capacity (UPS 12580 F2)	RL24010801-01	
	Discharge capacity (RUM 6290 F2)	RL24020501-01	